



FPB COPY

CITY OF BUFFALO

NEW YORK

DEPARTMENT OF FIRE
195 COURT STREET
BUFFALO, N. Y. 14202

JAMES D. GRIFFIN
MAYOR

FRED D. LANGDON
COMMISSIONER OF FIRE
855-5333

December 20, 1984

Mr. John Stachurski
Niagara Aromatics
254 Rano Street
Buffalo, New York 14207

RE: 254 Rano Street

Dear Mr. Stachurski:

In regard to our telephone conversation concerning the storage of chlorine gas cylinders, the Fire Prevention Code requires the following:

Inside storage in a room of one hour fire-resistive construction having natural ventilation. Legible warning signs stating the nature of hazard should be posted where the gas is stored.

Outside storage shall be screened or fenced-enclosed. Legible warning signs. The location discussed on the telephone - the loading dock area - seems to be an appropriate area.

All controls and piping must comply with accepted standards for such installation.

When the above-noted work has been completed, notify this office for an inspection and license recording.

Sincerely yours,

Chester Pawarski, Lieutenant
BUREAU OF FIRE PREVENTION
Buffalo Fire Department

CP/mc

371388



CITY OF BUFFALO
INTER DEPARTMENTAL CORRESPONDENCE

To Josephine B. Nickels
Executive Secretary
Zoning Board of Appeals

From Bureau of Fire Prevention
Department of Fire

Date April 23, 1982
Subject 254 Rano Street

254 RANO

An inspection of the above-noted premises regarding the manufacturing of chemicals was conducted on April 23, 1982.

Mr. John Stachurski of Niagara Technology Company had explained to this inspector the process and equipment involved. A new location for the mixing of flammable liquids had been inspected and found to be suitable. The area is aboveground and is properly enclosed because of its former use as a boiler room.

The basement area, which was originally proposed, will be used for producing chemicals which are not highly flammable.

The Fire Department will withdraw its objections and recommend approval on condition that the stairways be enclosed at the basement level.

Chester Pawarski, Lieutenant
BUREAU OF FIRE PREVENTION
Buffalo Fire Department

CP/mc

NT

JOHN Z. STACHURSKI
PRESIDENT

NIAGARA TECHNOLOGY CO.
220 KAYMAR DRIVE
TONAWANDA, N.Y. 14150

(716) 691-6131

12-14-84

*Niagara Aromatics Inc.**876-3341**2 cylinders Chlorine Gas
loading dock**ep*